

Copy of the Fire Safety Certificate issued by Fire Safety Officer, Rajkot Municipal Corporation



rfo-sfps-rajkot@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2023/00041557

Date: 12/03/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2023/00041557/R1

Building Occupancy/Category: Educational (non-residential)

To,

FRIENDS DREAM EDUCATION TRUST MOUNT LITERA ZEE SCH
MOUNT LITERA ZEE SCHOOL SADIPANI ROAD Porbandar PORBANDAR Porbandar 360575
Fire Region: Rajkot RFO
Mobile No: 7041757587 Email ID: porbandarmz@gmail.com

This has reference to your Application No. 2025/00111896 dated 08/03/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise MOUNT LITERA ZEE SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Porbandar
5. Name of Block(s): MOUNT LITERA ZEE SCHOOL

The building/premise was inspected on 12/03/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 12/03/2025
2. Six monthly inspection was done on 12/03/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 12/03/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Hitesh Khimaniya
Fire Safety Officer - General (FSO-G)
2021/001926

Date: 12/03/2025
Time: 06:17 PM



FSCA/O/RFORAJ/2023/00041557/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

FRIENDS DREAM EDUCATION TRUST

K. J. Patel

TRUSTEE

Shrinivastava

PRINCIPAL

MOUNT LITERA ZEE SCHOOL
PORBANDAR