

Copy of the Water Examination Report



Making
Analyte
Count

Page 1 of 1

TEST REPORT					
Report No: ECL/WAC/1011/24-25					
Issued to	Mount Litera Zee School Porbandar Behind Sandipani Ashram, Porbandar - 360577.				
Sample collected By	ECL Team Member (Mr. Nimesh)				
Sample Identity	Water	Test Report as per	IS : 10500:2012		
Sample Description	Drinking Water	Batch No.	----		
Quantity	1000 mL Approx.	Brand Name	----		
Date of Sampling	15/03/2025	Date of Mfg.	----		
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue		
15/03/2025	16/03/2025	18/03/2025	18/03/2025		
Organoleptic and Physical Parameters					
Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	REQUIREMENTS	RESULTS
1.	Color	IS : 3025 (Part-04) - 2021	Hazen	5 Max.	BDL (DL=1)
2.	Odour	IS : 3025 (Part-05) - 2018	----	Agreeable	Agreeable
3.	pH Value	IS : 3025 (Part-11) - 2022	----	6.5-8.5	7.18
4.	Taste	IS : 3025 (Part-07) - 2017	----	Agreeable	Agreeable
5.	Total Dissolved Solids (TDS)	IS : 3025 (Part-16) - 1984	mg/l	500 Max.	88.2
General Parameters Concerning Substances Undesirable in Excessive Amounts					
6.	Ammonia (as total ammonia-N)	IS : 3025(Part-55) - 2003	mg/l	0.5 Max.	BDL (DL=0.1)
7.	Chloride (as Cl)	IS : 3025(Part-32) - 1988	mg/l	250 Max.	26.8
8.	Nitrate (as NO ₃)	IS : 3025(Part-34) - 1988	mg/l	45 Max.	0.9
9.	Total Alkalinity (as CaCO ₃)	IS : 3025 (Part-23) - 1986	mg/l	200 Max.	48.4
10.	Total Hardness (as CaCO ₃)	IS : 3025 (Part-21) - 2009	mg/l	200 Max.	21.6
NOTE : *BDL = Below Detectable Limit					
On Analysis of all above parameters, the submitted sample CONFIRMS to the above specifications.					
<p>1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The Eurochem Laboratories LLP, RAJKOT.</p> <p>2 This test report is ONLY FOR THE SAMPLE TESTED.</p> <p>3 Sample drawn by us.</p>					
<p>Approved By: Mr. Jay J. Ramoliya (M.Sc. Chem.)</p> <p><i>[Signature]</i></p>			<p>Mr. Nandan Sorathiya (M.Sc. Microbiology)</p> <p><i>[Signature]</i></p>		
Authorize Signatory		SEAL		Signatory	

This is computer generated copy



+91 7999995772



info@eurochemlaboratories.com



www.eurochemlaboratories.com



Eurochem Laboratorie LLP Naval Nagar-5 Corner, Nr. Fire Brigade, Mavdi Main Road, Rajkot, Gujarat - 360004.

Every 3,000 sheets of paper cost us a tree. Let's conserve. Reuse paper whenever it's possible.

FRIENDS DREAM EDUCATION TRUST

[Signature]

TRUSTEE

[Signature]

PRINCIPAL
MOUNT LITERA ZEE SCHOOL
PORBANDAR